

§ 354.222

(d) Refuse rooms. Refuse rooms shall be entirely separate from other rooms in the plant, and shall have tight fitting doors and be properly ventilated.

(e) Storage and supply rooms. The storage and supply rooms shall be in good repair, kept dry, and maintained in a sanitary condition.

(f) Boiler room. The boiler room shall be a separate room, if necessary, to prevent its being a source of dirt and objectionable odors entering any room where ready-to-cook rabbits are prepared, processed, handled, and stored.

(g) Inspector's office. Furnished office space, including, but not being limited to, light, heat, and janitor service shall be provided rent free in the official plant for the exclusive use for official purposes of the inspector and the Administration. The room or rooms set apart for this purpose must meet with the approval of the regional supervisor and be conveniently located, properly ventilated, and provided with lockers or cabinets suitable for the protection and storage of supplies and with facilities suitable for inspectors to change clothing.

(h) Toilet rooms. Toilet rooms opening directly into rooms where rabbit products are exposed shall have self-closing doors and shall be ventilated to the outside of the building.

§ 354.222 Floors, walls, ceilings, etc.

(a) Floors. All floors in rooms where exposed products are prepared or handled shall be constructed of or finished with materials impervious to moisture, so they can be readily and thoroughly cleaned. The floors in killing, ice cooling, ice packing, eviscerating, cooking, boning, and cannery rooms shall be graded for complete runoff with no standing water.

(b) Walls, posts, partitions, doors. All walls, posts, partitions, and doors in rooms where exposed products are prepared or handled shall be smooth and constructed of materials impervious to moisture to a height of 6 feet above the floor to enable thorough cleaning. All surfaces above this height must be smooth and finished with moisture-resistant material.

(c) Ceilings. Ceilings must be moisture-resistant in rooms where exposed products are prepared or handled, and

9 CFR Ch. III (1-1-06 Edition)

finished and sealed to prevent collection of dirt or dust that might sift through flooring above or fall from collecting surfaces on equipment or exposed product.

§ 354.223 Drainage and plumbing.

There shall be an efficient drainage and plumbing system for the plant and premises.

(a) Drains and gutters. All drains and gutters shall be properly installed with approved traps and vents. The drainage and plumbing system must permit the quick runoff of all water from plant buildings, and surface water around the plant and on the premises, and all such water shall be disposed of in such a manner as to prevent a nuisance or health hazard.

(b) Sewage and plant wastes. (1) The sewerage system shall have adequate slope and capacity to remove readily all waste from the various processing operations and to minimize, and if possible to prevent, stoppage and surcharging of the system.

(2) Grease traps which are connected with the sewerage system shall be suitably located but not near any edible products department or in any area where products are unloaded from or loaded into vehicles. To facilitate cleaning, such traps shall have inclined bottoms and be provided with suitable covers.

(3) Toilet soil lines shall be separate from house drainage lines to a point outside the buildings unless they are positively trapped to prevent backing up. Drainage from toilet bowls and urinals shall not be discharged into a grease catch basin.

(4) All floor drains shall be equipped with traps, constructed so as to minimize clogging, and the plumbing shall be so installed as to prevent sewerage from backing up and from flooding the floor.

(5) Floor drainage lines should be of metal and at least 4 inches in diameter and open into main drains of at least 6 inches in diameter and shall be properly vented to outside air.

(6) Where refrigerators are equipped with drains, such drains should be properly trapped and should discharge